
THE OPERATION OF LAND POWER PLANTS 275

high percentages of nickel, and, some of them, a certain amount of platinum

and chromium.



Similar remarks are equally true of the valves used on the water side of the boilers. If more than sufficient soda is used the brass water-gauge and other fittings may be attacked, and so become

attacked, and so become expensive to maintain. The

maintenance of valves becomes a very serious matter where inferior material

is used, and the cost of maintenance per annum may quite easily prove

to be considerably more than the original capital cost of the valve or fitting involved.

Fig. 12.—Feed-water Density Indicator **Priming** Boilers. of The priming of boilers steam may become serious if exan soda cessive is amount of the present boiler in water. Some waters are naturally The high in soda. only step to take in that case is to blow out the entire water contents the drain of the boiler to frequently. This operation is known blowing down as other this In cases excess may be due too much soda to having been added for watertreatment It purposes. may, added however, have been in of the form Somebody's patent boiler composition. If power depends the station tidal or upon a water sea water for its circulating water system, leaky condenser tubes may allow sufficient salt to enter the condensed steam to cause will be priming. Tt. remembered that the condensed water is returned direct to boilers $\mathbf{b}\mathbf{v}$ the boiler feed-pumps in a condensing system—and this system is used for all modern plants. Contamination with salt water has proved

dangerous in many cases, and where the turbines have had their relay valves operated $\mathbf{b}\mathbf{v}$ steam, governors have sometimes been rendered inoperative, have allowed turbines to run away until the emergency governor has operation. come into In some cases, this trouble has led even to the destruction of the turbine plant.

There are many excellent devices on the market for indicating the condition of the condensate. Some of these devices test the water continuously and cause an alarm bell to ring directly the water reaches a predetermined value in density (fig. 12).